

MAXIMIZING PLANT CAPACITY A BIOMAG[®] IMPLEMENTATION

FLOYD BRANCH REGIONAL WASTEWATER TREATMENT PLANT

Roshan Thapa, NTMWD
Noel Pattengale, Arcadis
Tongren Zhu, Arcadis
January 25, 2019



NORTH TEXAS
MUNICIPAL
WATER
DISTRICT

AGENDA



Project Background - FBRWWTP



BioMag[®] Fundamentals



Pilot Set-Up and Schedule




Results and Recommendations



Project Background



Project Background – FBRWWTP



Project Background – FBRWWTP



- Location: City of Richardson
- Permitted Flow
 - AADF: 4.75 MGD
 - P2HF: 10 MGD
- Treatment Process
 - Trickling Filter Train (2.5 MGD)
 - Conventional Activated Sludge Train (2.25 MGD)
- Key Features
 - 1986 Expansion
 - 2009 Improvements
 - 2012 Odor Control Improvements
 - 2014 UV Improvements

Project Scope

Evaluation of the Plant to maintain current and future operations

- Condition Assessment and Scenario Planning
- Determination of improvements needed
 - Conventional Activated Sludge Expansion
 - Membrane Biological Reactors (MBRs)
 - BioMag[®] System

Criteria	Priority Weight*	Alt. 1 – Conventional AS		Alt. 2 – Parallel MBR Treatment Train		Alt. 3 – BioMag [®] System	
		Assigned Value**	Weighted Value***	Assigned Value**	Weighted Value***	Assigned Value**	Weighted Value***
Reliability	7	4	28	3	21	2	14
Safety	6	2	12	3	18	3	18
Constructability	5	4	20	1	5	2	10
Complexity	4	2	8	3	12	3	12
Maintenance	3	2	6	3	9	3	9
Regulatory	2	1	2	3	6	3	6
Expandability	1	5	5	2	2	3	3
Totals		81		73		72	

Pilot Scope

BioMag[®] Pilot

- Evaluate the biological treatment configuration
- Evaluate the treatment capacities
- Evaluate anticipated effluent quality
- Evaluate treatment chemistry/chemical doses
- Evaluate mixing requirements in basins and channels




BioMag[®] Fundamentals



Project Background – BioMag[®]

- Manufacturer: Evoqua Water Technologies
- Principle: Enhanced existing secondary treatment system with magnetite ballast
 - Enhance settleability of MLSS
 - Increase solids loading in secondary clarifiers
 - Increase MLSS in aeration basin to increase treatment capacity
- Benefits:
 - Increased Treatment Capacity without Additional Aeration Basins and Clarifiers


The BioMag[®] process



Pilot Set-Up and Schedule



BioMag[®] Pilot Set-Up








Only half of Aeration Basin and Secondary Clarifier Active

BioMag[®] Pilot Set-Up



Pilot Schedule

Total Duration: Aug 30 to Dec 6, 2017 (~4 months)

	AUG	SEPT	OCT	NOV
Pilot Trailer Arrival and Setup:				
System Start-Up:				
Testing Period:				
Stress Test I / P2H1:			Nov 8 (5.9 MGD, equals 11.7 MGD full plant)	
Stress Test II / P2H2:			Nov 17 (7.2 MGD, equals 14.3 MGD full plant)	



BioMag® WAS Feed
from RAS Blind Flange



BioMag® WAS to Pilot Trailer

Magnetite Dosing



Shear Mill



Mag Drum



Ballast Mix Return


Results and Recommendations




Floyd Branch Discharge Permit

Parameter	Daily Ave (mg/L)	7-day Ave (mg/L)	Daily Max (mg/L)	Single Grab (mg/L)
cBOD ₅	10	15	25	35
TSS	15	25	40	60
NH ₃ -N (Mar-Nov)	2	4	10	15
NH ₃ -N (Dec-Feb)	4	6	10	15

Solids Concentration in Aeration Basin




Secondary Effluent Results – cBOD₅



>98% cBOD₅ Removal

cBOD₅ was always lower than 10 mg/L and meet discharge limit


Secondary Effluent Results – TSS



>97% TSS Removal

TSS was always lower than 10 mg/L and met discharge limit


Secondary Effluent Results – NH₃-N



>99% NH₃-N Removal

NH₃-N was always lower than 2 mg/L and met discharge limit

Secondary Effluent Results – Turbidity



Only one single point exceeded turbidity target of 3 NTU


Secondary Effluent Data Summary

Parameter	Permit Daily Ave	Permit 7-day Ave	Pilot Ave Result
cBOD ₅ (mg/L)	10	15	3.7
TSS (mg/L)	15	25	4.2
NH ₃ -N (mg/L) (Mar-Nov)	2	4	0.21
NH ₃ -N (mg/L) (Dec-Feb)	4	6	

Stress Test Effluent Results






Condition	Permit Daily Ave	Permit Daily Max	P2H1 (5.9 MGD)	P2H2 (7.2 MGD)
cBOD ₅ (mg/L)	15	25	7	7.8
TSS (mg/L)	10	40	7.9	6.6
NH ₃ -N (mg/L) (Mar-Nov)	2	10	2.17	0.598
Turbidity (NTU)	N/A	N/A	2.84	2.32

Polymer Use at Secondary Clarifier






Certain polymer should be dosed based on site-specific conditions. Polymer dose gradually decreased as flow rate increased

Results Summary


-  The Pilot demonstrated BioMag[®]'s ability to treat AADF and P2H with existing facilities
-  Clarifier overflow rate of 1430 gpd/sf and increased solids loading
-  The secondary effluent was consistently below the permitted parameters
-  The BioMag[®] successfully showed the ability to obtain a variance on the filter process
-  Full suspension of magnetite floc was maintained in the Aeration Basin

Recommended Optimizations


-  Extend the height of the Aeration Basins baffle walls to accommodate increased flow
-  Optimize flow path to reduce settling
-  Consider versatility in polymer injection points to optimize the reaction time and mixing energy.



Aeration Basin Flow Path Optimization



Existing



Proposed



Project Scope

BioMag[®] Pilot



Evaluate the biological treatment configuration



Evaluate the treatment capacities



Evaluate anticipated effluent quality



Evaluate treatment chemistry/chemical doses



Evaluate mixing requirements in basins and channels



Acknowledgement



NORTH TEXAS
MUNICIPAL
WATER
DISTRICT



ARCADIS | Design & Consultancy
for natural and
built assets



eVOQUA
WATER TECHNOLOGIES



Questions?



ROSHAN THAPA
Project Manager

o 469 626 4739
e rthapa@ntmwd.com

NOEL PATTENGALE, PE
Certified Project Manager

o 972 663 2160
e noel.pattengale@arcadis.com

