

Playing 3-Shell Monte with Peak Flows – A Technical-Economical Analysis of Storm Flow Management Alternatives

Rudy E. Kilian, P.E.

Carollo Engineers

July 21, 2023



Names for Wet-weather treatment


- Wet-weather treatment
- Blending (out-dated)
- Parallel Treatment
- Select Treatment
- Storm Flow Auxiliary Treatment

Why Consider Wet Weather Treatment

- Higher intensity storms and I&I are affecting utilities' performance during peak flow events.
- Handling peak flow in main treatment trains results in a large footprint that is not feasible to accommodate within site limitations/constraints.
- Designing the main treatment train for the peak flow results in high capital costs and facilities that remain unused for most of the year.

Regulatory Background

TCEQ 217.B.(1) requires the use of 2-year 24-hour storm event





Wet Weather - Regulatory Background

- **Prior to 1994:** Blending used to treat excess wet weather flow »Non-uniform acceptance of blending practice by EPA regions
- **1994:** CSO Policy establishes basis for "CSO-related bypass"
 » Blending for WWTPs served by <u>separate sewer systems</u> not addressed
- 2005: EPA proposal mirroring approach taken by 1994 CSO Policy
 » Blending would be authorized as an anticipated bypass if a "No Feasible Alternatives Analysis" was conducted
 - » Never released by OMB

Wet Weather - Regulatory Background

- **Post-2005:** EPA Headquarters took the position that blending had ALWAYS been a bypass
 - » EPA Headquarters took the position that all WWTPS served by <u>separate</u> <u>sewer systems</u> must provide <u>biological treatment</u> to <u>ALL flows</u>
- 2013: 8th Circuit Decision *Iowa League of Cities v EPA*
 - » Court found that EPA was improperly applying 2005 policy (proposal) as a rule
 - » CWA secondary treatment standards apply only at "end of pipe"
 - » EPA is only applying ruling within 8th Circuit jurisdiction
- 2018: EPA announces plan for rulemaking to resolve blending issue
 » Rule not released by time previous Administration ended. Presumed dead.

TSS and CBOD5 Performance – CFR § 133.101&102

	Stipulated Effluent Criteria	
Parameter	30-day Average	7-day Average
TSS, mg/L	30	45
BOD ₅ , mg/L	30	45

Facilities eligible for treatment equivalent to secondary treatment.

(1).....

(2).....

(3) The <u>treatment works</u> provide significant biological treatment of municipal wastewater

Potential Treatment Options

- Without Biological Step
 - » Primary Filters
 - Cloth media
 - Compressible media
 - Ceramic membrane
 - » Chemically Enhanced Primary Filtration
 - » High-rate Clarification
 - Sand ballasted systems (e.g. Actiflo[®], Dynasand)
 - Magnetite ballasted systems (Co-mag)
 - High solids contact systems (DensaDeg
- With Biological Step
 - » Bio-Actiflo®
 - » Bio-Mag
 - » Contact Stabilization plus clarification
- Other
 - » Step-Feed in Aeration Basins
 - » Equalization

Non-Economic Comparison of Wet Weather Treatment Options

TREATMENT TYPE	ADVANTAGES	DISADVANTAGES
Peak Flow Storage	Reduces size of treatment processes and effluent outfall. Does not rely on combining effluents to meet effluent limits. Does not require special approval by regulators.	Larger footprint than auxiliary treatment. Potential odor concerns. Basin wash-down is labor-intensive. Limited sustained peak flow capacity. When it's full, it's full.
Secondary Treatment Enhancements	Does not rely on combining effluents to meet effluent limits. For conventional processes, it does not require special approval by regulators.	Providing more or larger clarifiers is costly and requires a large footprint. Biological system may become stressed during peak flow events. May add complexity to secondary system operation.
Auxiliary Treatment	Smaller footprint than other alternatives. Can handle sustained design peak flow. Certain technologies can serve dual purpose (tertiary and wet weather treatments).	Relies on combining effluents to meet permitted limits. Lower treatment efficiency than the main treatment train. Limited number of full-scale installations. Backwash or solids wasting must be returned upstream of primary clarifiers. May require special approval by regulators.

Calculating Storm Impacts on Facility



ISWM 2-Year 24 Hour Storm Event

iSWM[™] Technical Manual

Hydrology

1000

1.299

2.055

2.568

3.557

4,757

6.363

7.460

9.363

11.194

13.105

15.074

16.444

17.659

20.548


22.567

26.559

29.657

34.576

39.080



8.254

10.090

11.723

30-day

45-day

60-day

8.968

10.933

12.687

11.704

14.181

16.403

13,798

16.657

19.233

16.614

19.966

23.012

18,752

22.475

25.891

20.998

25.066

28.826

23.431

27.801

31.841

26.872

31.580

35.918


Table 5.3 AMS-based precipitation frequency estimates for Denton County (inches)

Average recurrence interval (years)


TCEQ 217.B.(1) requires the use of 2-year 24-hour storm event

indatefooter0323 nntx/1

Example Storm Event




Plant Meter Data




CAROLLO / 13

Rain Events – April 17, 2016



Rain Events – September 21/22, 2018


September 21, 2018 Rain Event



15

Rain Events – September 21/22, 2018

September 21, 2018 Rain Event




16

Treatment




Increasing secondary treatment to manage storm flows is expensive and unnecessary




Storage






Phase 1A – Modifications to Meet Current Permit

60






pdatefooter032


Emergency Storm Treatment



Typical Flow Schematic




Proposed Storm-Treatment Filters



Selecting the right storm treatment reduces capital costs for improvements







Questions

Click to edit text

