




# It's A Gritty Situation: Tackling Grit at Village Creek Water Reclamation Facility

January 29, 2021 TACWA Meeting

Amy Robinson, PE, BCEE, CDM Smith



# Presentation Overview

- Village Creek Water Reclamation Facility (VCWRF)
- Grit Characterization and Profiling
- Grit Facility Location Strategy
- Grit Technology Evaluation
- Physical Modeling
- Design 3D Model

## Village Creek 1958



- “In the middle of no-where”
- Initial Capacity 5 MGD to serve East Fort Worth
- Built to replace Riverside WWTP
- Population of Fort Worth 350,000

## Village Creek WRF Now


- Now serves around 1.2 million people including 880,000 Fort Worth residents, 23 communities in Tarrant and Johnson Counties
- Permitted for 166 mgd AADF and 369 mgd 2-hr peak
- Conventional WWTP
- No influent grit removal process
- Primary sludge de-gritting system





# Grit Sampling & Characterization Studies

- September 2012 - influent & primary sludge
- June 2013 – influent & Salsnes Filter
- October 2015 – Digesters
- April-June 2016 existing primary sludge de-gritting system and slurry cup pilot
- April 2017 – Aeration Basin 6
- May 2017 – Sludge Holding Tank at Solids Dewatering Facility
- September 2017 – influent and primary sludge



# Grit Characterization and Profiling

	Average Grit Particle Distribution		
Particle Size	≤105μm	≤150μm	≤297μm
Influent Box E	5.3%	13.5%	34.4%
Influent Box F1	9.3%	21.3%	50.0%
Influent Box C/Bar Screen 3	9.1%	23.0%	53.9%
<b>Average</b>	<b>7.9%</b>	<b>19.3%</b>	<b>46.1%</b>

Predicted Removal Efficiency of System Designed for Particular SES <sup>1</sup>		
105μm	150μm	297μm
96%	78%	31%


1. SES is Sand Equivalent Size – sand particle size (microns) having same settling velocity as the selected grit particle

# Grit Characterization and Profiling

Location	Average Grit Concentration	
	lb/MG	mg/L
Influent Box C	67	8
Bar Screen 3	38	5
Influent Box F1	396	48
Influent Box E	115	14
Average	186	22

# Grit Handling Mass Balance


## Existing System





# Grit Handling Mass Balance

## System Design for 105 Micron Removal




# Grit Facility Design Criteria

Flow Scenario	Total Plant Flow	HRC Flow	Grit Facility Design Flow	Performance Cutpoint
Design AADF, mgd	166	0	166	≥105μm
2030 AADF, mgd	189	0	189	≥105μm
SPTC, mgd	365	110	255	≥150μm
PHF, mgd	494	110	384	≥212μm

AA DF – annual average daily flow; PHF – peak hour flow  
 SPTC - sustainable peak treatment capacity (extended 3-day peak treatment)


# Grit Facility Location Strategy

- Address all flow  
75-80% West  
20-25% South
- South flow screening (BS3)
- Utilize existing Headworks screening capacity
- Collection system impacts






# Grit Facility Location - Option 1



- Combined Grit Facility for West and South flow
- New Screen Facility for South flow
- Screening and grit handling in 2 locations
- Requires significant collection system improvements for south flow




# Grit Facility Location - Option 2



- Combined Grit Facility for West and South flow
- New Screen Facility for South flow
- 124 MGD intermittent Peak Flow Lift Station for South flow to minimize collection system improvements



# Grit Facility Location - Option 3



- Combined Grit Facility for West and South flow
- Upgrade existing Headworks Facility
- Full service 124 MGD Lift Station for South Flow

# Life Cycle Cost Analysis

	Grit Facility Location 1	Grit Facility Location 2	Grit Facility Location 3
Capital Cost	\$46,900,000	\$44,440,000	\$35,200,000
Operations and Maintenance Cost	\$14,100,000	\$18,300,000	\$32,300,000
Total Present Worth	\$61,000,000	\$62,740,000	\$67,500,000

- Life Cycle in years = 20
- Discount rate = 5%
- Inflation rate = 2%
- P/A factor = 14.96

# Grit Technology Evaluation

- Grit Separation
- Grit Pumping
- Grit Processing
  
- Recommendation → Separate each component for evaluation



# Grit Technology Evaluation Criteria

- Independent performance testing acceptance
- Installations for fine grit removal (105-micron)
- Operation and maintenance perspective
- Life cycle cost

# Grit Separation Evaluation Summary

Criteria	Mechanically Induced Forced Vortex	Stacked Tray Forced Vortex
Performance	Average	Good
Head Loss	Similar Under Optimal Design Conditions	Similar Under Optimal Design Conditions
Footprint (single unit)	Large	Small
Screening Required	Yes	Yes
Maintenance	Medium	Low
Installations of Similar Size	Many (Fewer with V-force baffle)	Few (140 total, 3+ of similar size)
Other	Long Approach Channels	Sole Source

# Stacked Tray Forced Vortex Sizing

Maximum Flow for Single 12 Tray HeadCell <sup>®</sup> (Mgal/d)				
		Cutpoint Performance		
Tray Diameter	Area ft <sup>2</sup> (m <sup>2</sup> )	106 μm	150 μm	212 μm
4' (1.2 m)	150 ft <sup>2</sup> (13.9 m <sup>2</sup> )	2.6	4.0	5.1
6' (1.8 m)	340 ft <sup>2</sup> (31.6 m <sup>2</sup> )	5.8	9.0	11.5
9' (2.7 m)	763 ft <sup>2</sup> (70.9 m <sup>2</sup> )	13.0	20.2	26.0
12' (3.7 m)	1356 ft <sup>2</sup> (125.9 m <sup>2</sup> )	23.1	36.0	46.1

Cutpoint Performance	Loading Rate	
	gpm/ft <sup>2</sup>	L/m <sup>2</sup>
75 μm	6.9	4.7
106 μm	11.8	8.0
125 μm	15.6	10.6
150 μm	18.4	12.5
175 μm	21.1	14.3
212 μm	23.6	16.0

166 MGD Grit Facility Flow / 23.1 MGD/ Unit Capacity → **8 Units**  
 255 MGD Grit Facility Flow / 23.1 MGD/ Unit Capacity = → **12 Units**

# Mechanically Induced Forced Vortex Sizing

Peak Hour Flow, MGD	Diameter, ft.	Chamber Depth, ft.	Hopper Diameter, ft.	Hopper Depth, ft.	Calculated Detention Time, sec.
1	6	3.67	3	5	67
2.5	7	4.5	3	5	45
4	8	4.67	3	5	38
7	10	5	3	5.5	36
12	12	6.67	5	6.67	41
20	16	7.5	5	6.83	49
30	18	9.17	5	7	50
50	20	11.5	5	7	47
70	24	12.67	6	8	53
100	32	12.67	8	10	66

- Does not use particle settling theory
- Particle separation depends on liquid flow pattern creating forces acting in tangential, vertical, and radial directions.
  - Particle Force Balance Equation (i.e. drag, centrifugal, buoyancy)
  - Particle Diameter Equation to determine particle diameter cut-off that will separate from fluid flow
  - CFD analysis to determine grit path through unit



# Mechanically Induced Forced Vortex Sizing

Manufacturer	Unit Size	No. of Units Per Manufacturer	No. of Units (1.5 SF)	No. of Units (2 SF)	No. of Units (Settling Theory)
Smith & Loveless	70.0 MGD	4	6	8	34*
John Meunier	76.8 MGD	5	8	10	34*

\*Based on grit settling velocity of 105 micron particle size 11.8 gpm/sf

# Grit Pumping

- Pump Configuration




Flooded Suction



Top-Mounted Self-Priming

- Pump Type – Recessed Impeller



# Grit Pumping – Other Considerations

- Simple pipe alignment
- Minimize bends
- Long radius bends
- Proper flushing connections and cleanouts
- Pump Seals



# Grit Processing Evaluation Summary

Criteria	Cyclone/Classifier	SlurryCup/GritSnail	Cone Washer
Claimed Grit Capture (best case)	95% of Grit $\geq$ 100 $\mu$ m	95% of Grit $\geq$ 75 $\mu$ m	95% of Grit $\geq$ 100 $\mu$ m
Washed Grit Water Content	$\leq$ 25%	$\leq$ 40%	$\leq$ 10%
Washed Grit Organic Content	$\leq$ 50%	$\leq$ 15%	$\leq$ 5%
Hydraulic Capacity	High	Medium	Medium
Manufacturers	Many	One	One (possibly two)
Maintenance	High	High	Low



# Grit Removal System Direct Cost Summary

Component	Mechanically Induced Forced Vortex (8 units)	Stacked Tray Vortex (8 units) 105 micron @ 166 mgd	Stacked Tray Forced Vortex (12 units) 105 micron @ 255 mgd
Grit Separation Equipment	\$680,000	\$1,500,000	\$2,250,000
Grit Separation Tanks (concrete)	\$1,300,000	\$1,100,000	\$1,500,000
Grit Pumps	\$480,000	\$400,000	\$550,000
Grit Processing	\$1,200,000	\$1,100,000	\$1,600,000
Other Cost (gates, piping, HVAC, etc.)	\$1,200,000	\$1,200,000	\$1,300,000
Grit Building	\$460,000	\$460,000	\$460,000
<b>SUBTOTAL Direct Cost</b>	<b>\$5,360,000</b>	<b>\$5,760,000</b>	<b>\$7,660,000</b>
Cost per Unit	\$612,500	\$662,500	\$600,000

Notes:

1. Cost presented above are +/- 30% at this 15% conceptual level of estimation.
2. Cost presented are direct cost only. Bonds, insurance, and OH&P are not included.
3. Cost presented related to grit separation, pumping and processing only and does not include overall project costs such as yard piping, site work, screening, lift station cost, etc.

## Design Criteria

- Grit Separation: stacked tray forced vortex units
  - 95% removal efficiency 105µm and greater
- Grit Pumping: flooded suction recessed impeller pumps
- Grit Processing: cone washer/screw conveyors
  - 95% removal efficiency
  - < 10% water content
  - < 5% organic content

# Physical Modeling



Physical Model Overview



Influent Splitter Box

# Physical Modeling



Headcell Influent Channel Isolation Gates



Headcell Influent Channel



# Physical Modeling




Influent Splitter Box Modification




Removed Influent Channel Gates

# Influent Splitter Box Modifications




Influent Splitter Box Modification  
Plan View




Influent Splitter Box Modification  
Section View

# Influent Splitter Box Modifications





Influent Splitter Box Modification  
Plan View



Influent Splitter Box Modification  
Section View



# Physical Modeling



Weir Widths Equal For All Head Cells (Submerged Flow)

Influent Diversion Box WSE (need to add 12-in for Headcell (475.50))


- Issues:
1. Submerged Weirs and Influent
  2. Splitter Box WSE exceed goal of 474.25



# Physical Modeling




Revised S-Bend in South Channel




Tapered Wall in North Influent Channel

# Physical Modeling




Headcell Weir Final Setting at 471.50




Tapered Wall in North Influent Channel



# VC Grit Facility 3D Model




# VC Grit Facility 3D Model





# VC Lift Station 3D Model



# Thank You

Amy Robinson, P.E., BCEE  
CDM Smith Inc.  
[robinsonar@cdmsmith.com](mailto:robinsonar@cdmsmith.com)

